WATER QUALITY REPORT 2024 FOR CLAIRMONT MANOR SUBDIVISION - PWSID #6047040

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. We have met all Virginia State drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

No special precautions are necessary; however some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

The source of your drinking water is ground water. Clairmont Manor has two wells to support the subdivision.

- Well A: This well is located in the Clairmont Manor Subdivision in Culpeper County, VA.
- •Well B: This well is located in the Clairmont Manor Subdivision in Culpeper County, VA.

Source water assessment and its availability

The Virginia Department of Health (VDH) conducted a source water assessment of your system. The wells were determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program. The assessment report consists of maps showing the source water assessment area, an inventory of known land use activities of concern, and documentation of any known contamination. The report is available by contacting the VDH at 540-829-7340.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have questions about this report, or if you want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact: Country Water Systems at 540-825-2781.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers a 5 minute shower uses 4 to 5 gallons of water compared to up to 50gal/month.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500gal/month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750gal/month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000gal/month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a more efficient model can save up to 1,000gal/month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a
 message next to the street drain reminding people "Dump No Waste Drains to River" or "Protect Your
 Water." Produce and distribute a flyer for households to remind residents that storm drains dump
 directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Clairmont Manor is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

October 2024 service line inventory was completed and no lead service lines were detected.

Other Information

Treatment of your drinking water supply:

- •A soda ash solution is injected into the water system for corrosion control.
- •A chlorine solution is injected into the water for disinfection.

For more information please contact:

Country Water Systems / Commonwealth Utilities, Inc.

P.O. Box 520 ♦ Culpeper, VA 22701

Phone: 540.825.2781 ♦ Fax: 540.825.8208

Water Quality Data Table for Clairmont Manor

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently

Combined (ppm) 10 10 3.34 3.28 3.34 2024 No Erosion of natural deposits Barium (ppm) 2 2 0.0415 .0195 0.0415 2024 No Discharge of drilling wastes; Discharge from metal refineries Erosion of natural deposits; Leaching Fluoride (ppm) NR NR 55.9 22 55.9 2024 No Erosion of natural deposits; Leaching Fluoride (ppm) 4.0 4.0 0.10 0.10 0.10 0.10 2024 No Erosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 226/228)(pCi/L) 0 5 .2987 .0882 .2987 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .7									us t	o monitor	for certain	contaminants less than once per yea
Contaminants	because the concentra			aminants T	do not	change fre	equently.					
Disinfectants & Disinfectant By-Products (There is convircing evidence that addition of a disinfectant is necessary for control of microbial contaminants) Chlorine (as Cl2) (ppm) 4 4 1 1.07 0.44 1.56 2024 No Water additive used to control microbes Halacactic Acids (HAAS) (ppb) NA 60 2.0 NA NA 2023 No By-product of drinking water chlorination TiTHMs [Total Trihalomethanes] (ppb) NA 80 .72 NA NA 2023 No By-product of drinking water chlorination Inforganic Contaminants Nitrate/Nitrite Combined (ppm) 10 10 3.34 3.28 3.34 2024 No Excision of natural deposits Barium (ppm) 2 2 0.0415 0195 0.0415 2024 No Excision of natural deposits Sodium (optional) (ppm) NR NR 55.9 22 55.9 2024 No Excision of natural deposits: Leaching From metal refineries Excision of natural deposits: Leaching Excision of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 262(228)(pcil.) 0 5 2.987 0.882 2.987 2023 No Excision of natural deposits Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 262(228)(pcil.) 0 15 .767 660 .767 2023 No Excision of natural deposits Discharge from fertilizer and pcil.) No Decay of natural and man-made deposits. The EPA conside (pcil.) 0 15 .767 660 .767 2023 No Decay of natural and man-made deposits. The EPA conside (pcil.) No Solution (TCR) (pcil.) No Decay of natural deposits (Seceeting AL Typical Source (Consumer Taps) (Consumer Taps) (Data (Pcil.) No Solution (TCR) (pcil.) No Corrosion of household plumbing systems (ppm) (pcil.) No Solution (Pcil.) No Corrosion of household plumbing systems (ppm) (pcil.) No Solution (pcil.) No Corrosion of household plumbing systems (pcil.) No Corrosion of household plumbing systems (pcil.) No Corrosion of household plumbing systems (pcil.) No Corrosion (pcil.) No Corrosion (pcil.) No Corrosion (pcil.) No Corrosion (p	Contaminante	or	TT, or						ion			Typical Source
Chlorine (as Cl2) (ppm) 4 4 4 1.07 0.44 1.56 2024 No Water additive used to control microbes Haloacetic Acids (HAAS) (ppb) NA 60 2.0 NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) TITHMS [Total Trihalomethanes] (ppb) NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) TITHMS [Total Trihalomethanes] (ppb) NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) NA NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) NA NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) NA NA 2023 No By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 No By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO By-product of drinking water chlorination (HAAS) (ppb) NA NA 2024 NO Sicharge from fertilizer use; Leaching from septic tanks, seware frosion of natural deposits (Prosion of natural deposits (HAAS) (ppb) NA NA 2024 NO Sicharge from metal refineries from fertilizer and aluminum factories (ppb) NA NA NA 2024 NO Sicharge from fertilizer and aluminum factories (ppb) NA NA NA 2024 NO NA Prosion of natural deposits (Pph) NA NA NA 2024 NO NA NA NA NA 2024 NO NA NA NA NA 2024 NO NA NA NA NA NA NA 2024 NA NA NA NA NA NA NA 2024 NA NA NA NA NA NA NA NA NA 2024 NA	Contaminants	WINDLG	MKDL	vvaler	LOW	підп	Date	violati	.1011			Typical Source
Haloacetic Acids (HAA5) (ppb) NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination Trihalomethanes] (ppb) NA 80 7.2 NA NA 2023 No By-product of drinking water chlorination Inorganic Contaminants Nitrate/Nitrite Combined (ppm) 10 10 3.34 3.28 3.34 2024 No Erosion of natural deposits Barium (ppm) 2 2 0.0415 0.195 0.0415 2024 No Discharge of drilling wastes; Discharge from metal refineries Erosion of natural deposits Sodium (optional) (ppm) NR NR 55.9 22 55.9 2024 No Erosion of natural deposits Elucide (ppm) 4.0 4.0 0.10 0.10 0.10 2024 No Erosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 226/228) (pci/L) Alpha emitters (pCi/L) Alpha emitters (pCi/L) O 50 1.01 0.70 1.01 2023 No Erosion of natural deposits. The EPA conside (pCi/L) Microbiological Contaminants Total Coliform (TCR) (positive O 1 1 1 NA NA 2024 No Naturally present in the environment Lead & Copper (Consumer Taps) MCLG AL Result Range Sample #Samples Exceeding AL Typical Source Capper - action level at consumer taps (ppm) 1.3 1.3 0.138 0.0455 - 0.175 2024 0 No Corrosion of household plumbing systomsumer taps (ppb) Na By-product of drinking waster chlorination By-product of drinking water chlorination Burlanding and subject subje	Disinfectants & Disinfe	ctant By-P	roducts	(There is cor	vincing e	vidence that ad	dition of a	disinfecta	ant is	necessary fo	or control of mic	robial contaminants)
(HAA5) (ppb) NA 80 .72 NA NA 2023 No By-product of drinking water chlorination TiTHMs [Total Trihalomethanes] (ppb) NA 80 .72 NA NA 2023 No By-product of drinking water chlorination Inorganic Contaminants Nitrate/Nitrite Combined (ppm) 10 10 3.34 3.28 3.34 2024 No Brosion of natural deposits Barium (ppm) 2 2 0.0415 .0195 0.0415 2024 No Brosion of natural deposits Sodium (optional) (ppm) NR NR 55.9 22 55.9 2024 No Brosion of natural deposits Sodium (optional) (ppm) NR NR 55.9 22 55.9 2024 No Brosion of natural deposits: Leaching Fluoride (ppm) 4.0 4.0 0.10 0.10 0.10 2024 No Brosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 20 5 2.987 .0882 .2987 2023 No Brosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 0 5 1.01 0.70 1.01 2023 No Brosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Total Coliform (TCR) (positive No Discharge from fertilizer and Samples/month) Lead & Copper (Consumer Taps) MCLG AL Result Range Date # Sample Exceeding AL Typical Source Lead & Copper (Consumer Taps) 1.3 1.3 0.138 0.0455 - 0.175 2024 0 No Corrosion of household plumbing systems and source taps (ppm) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 < 2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb) 1.5 4.26 1.5 4.26 1.5 5.68 2024 0 No Corrosion of household plumbing systems and source taps (ppb)	, , , , ,	4	4	1.07	0.44	1.56	2024	No		Water add	itive used to	control microbes
Trihalomethanes] (ppb) NA 80 7.2 NA NA 2023 NO By-product of drinking water chlorination (Inorganic Contaminants) No Brossion of natural deposits No By-product of drinking water chlorination (Inorganic Contaminants) No By-product of drinking water chlorination (Inorganic Contaminants) No Brossion of natural deposits No Brossion of natural deposits: Discharge from fertilizer and aluminum factories No Brossion of natural deposits No Brossion of natural dep	(HAA5) (ppb)	NA	60	2.0	NA	NA	2023	No	1	By-product of drinking water chlorination		water chlorination
Nitrate/Nitrite Combined (ppm)		NA	80	.72	NA	NA	2023	No	١	By-product of drinking water chlorination		
Combined (ppm) 10 10 3.34 3.28 3.34 2024 No Erosion of natural deposits Barium (ppm) 2 2 0.0415 0.195 0.0415 2024 No Discharge of drilling wastes; Discharge from metal refineries Erosion of natural deposits; Leaching Fluoride (ppm) NR NR 55.9 22 55.9 2024 No Erosion of natural deposits; Leaching Fluoride (ppm) 4.0 4.0 0.10 0.10 0.10 2024 No Erosion of natural deposits; Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 226/228)(pCi/L) 0 5 .2987 0.882 2.987 2023 No Erosion of natural deposits Alpha emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Decay of natural and man-made deposits. The EPA conside pCi/L to be the level of concern for Beta particles. Microbiological Contaminants Total Coliform (TCR) (positive samples/month) MCLG AL Result Range Date Exceeding AL Typical Source Copper - action level at consumer taps (ppm) 1.3 1.3 0.138 0.0455 - 0.175 2024 0 No Corrosion of household plumbing systems and the consumer taps (ppm) Lead - action level at consumer taps (ppb) 0 15 4.26 <2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and the consumer taps (ppb)	Inorganic Contaminant	s										
Sodium (optional) (ppm) NR NR 55.9 22 55.9 2024 No Erosion of natural deposits Leaching Fluoride (ppm) 4.0 4.0 0.10 0.10 0.10 0.10 2024 No Erosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 226/228)(pCi/L) 0 5 .2987 0.882 .2987 2023 No Erosion of natural deposits: Discharge from fertilizer and aluminum factories Alpha emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 50 1.01 .070 1.01 2023 No Decay of natural and man-made deposits. The EPA conside pCi/L to be the level of concern for Beta particles. Microbiological Contaminants Total Coliform (TCR) (positive Samples/month) NA NA 2024 No Naturally present in the environment Lead & Copper (Consumer Taps) MCLG AL Result Range Date Exceeding AL Typical Source Copper - action level at consumer taps (ppm) 1.3 1.3 0.138 0.0455 - 0.175 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.5 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) 2.5 5.9 5.0 5		10	10	3.34	3.28	3.34	2024	No		Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits		
Fluoride (ppm) 4.0 4.0 0.10 0.10 0.10 2024 No Erosion of natural deposits: Discharge from fertilizer and aluminum factories Radiological Contaminants Combined Radium 226/228)(pCi/L) 0 5 2987 0.882 2987 2023 No Erosion of natural deposits Alpha emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 50 1.01 .070 1.01 2023 No Decay of natural and man-made deposits. The EPA conside pCi/L to be the level of concern for Beta particles. Microbiological Contaminants Total Coliform (TCR) (positive samples/month) Copier - action level at consumer Taps (ppm) Lead & Copper (Consumer Taps) (ppm) Lead - action level at consumer taps (ppm) AL 0.10 0.10 0.10 0.10 0.10 0.10 0.10 0.1	Barium (ppm)	2	2	0.0415	.0195	0.0415	2024	No		Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits		
Radiological Contaminants Combined Radium 226/228)(pCi/L) 0 5 .2987 .0882 .2987 2023 No Erosion of natural deposits Alpha emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters 0 50 1.01 .070 1.01 2023 No Decay of natural and man-made deposits. The EPA conside pCi/L to be the level of concern for Beta particles. Microbiological Contaminants Total Coliform (TCR) (positive samples/month) Coper - action level at consumer taps (ppm) Lead & Copper (Consumer Taps) (pDm) 1.3 1.3 0.138 0.0455 - 0.175 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm) Lead - action level at consumer taps (ppb) 0 15 4.26 <2.5 - 5.68 2024 0 No Corrosion of household plumbing systems and consumer taps (ppm)	Sodium (optional) (ppm)	NR	NR	55.9	22	55.9	2024	No				
Combined Radium 226/228)(pCi/L) 0 5 .2987 .0882 .2987 2023 No Erosion of natural deposits Alpha emitters (pCi/L) 0 15 .767 .660 .767 2023 No Erosion of natural deposits Beta/photon emitters (pCi/L) 0 50 1.01 .070 1.01 2023 No Decay of natural and man-made deposits. The EPA conside (pCi/L) Microbiological Contaminants Total Coliform (TCR) (positive samples/month) 0 1 1 NA NA 2024 No Naturally present in the environment Lead & Copper (Consumer Taps)	Fluoride (ppm)	4.0	4.0	0.10	0.10	0.10	2024	No				
Solution	Radiological Contamin	ants										
Beta/photon emitters 0 50 1.01 .070 1.01 2023 No Decay of natural and man-made deposits. The EPA consider pCi/L to be the level of concern for Beta particles. Microbiological Contaminants Total Coliform (TCR) (positive samples/month) NA		0	5	.2987	.0882	.2987	2023	No	ı	Erosion of natural deposits		
Microbiological Contaminants Total Coliform (TCR) (positive samples/month) Align: Consumer Taps Copper - action level at consumer taps (ppm) Lead - action level at consumer taps (ppb) Copper (pp) Copp		0	15	.767	.660	.767	2023	No				
Total Coliform (TCR) (positive samples/month) Consumer Taps Consumer Taps		0	50	1.01	.070	1.01	2023	No				
(positive samples/month) Copper Consumer Taps Copper - action level at consumer taps (ppm) Lead - action level at consumer taps (ppb) Copper - action level	Microbiological Contar	minants										
Lead & Copper (Consumer Taps)MCLGALResultRangeDateExceeding ALALTypical SourceCopper - action level at consumer taps (ppm)1.31.30.1380.0455 - 0.17520240NoCorrosion of household plumbing systemsLead - action level at consumer taps (ppb)0154.26<2.5 - 5.68	(positive	00	1	1	NA	NA	2024	No		Naturally present in the environment		e environment
Lead & Copper (Consumer Taps)MCLGALResultRangeDateExceeding ALALTypical SourceCopper - action level at consumer taps (ppm)1.31.30.1380.0455 - 0.17520240NoCorrosion of household plumbing systemsLead - action level at consumer taps (ppb)0154.26<2.5 - 5.68				90 th %			Sam	ple	# 5	Samples	Exceeds	
consumer taps (ppm) 1.3 1.3 0.138 0.0455 - 0.175 2024 0 No Corrosion of household plumbing systems consumer taps (ppb) 1.5 4.26 <2.5 - 5.68 2024 0 No Corrosion of household plumbing systems consumer taps (ppb)	(Consumer Taps)	MCLG	AL		i	Range		•	Exceeding			Typical Source
consumer taps (ppb) 0 15 4.26 <2.5 – 5.68 2024 0 No Corrosion of household plumbing sys	consumer taps (ppm)	1.3	1.3	0.138	0.04	55 - 0.175	2024			0	No	Corrosion of household plumbing systems
Unit Descriptions & Important Definitions		0	15	4.26	<2	.5 – 5.68	2024			0	No	Corrosion of household plumbing systems
	Unit Descriptions & Im	portant Def	finitions									

Unit Descript	ions & Important Definitions					
ppm	parts per million, or milligrams per liter (mg/L)	pCi/L	Picocuries per liter (a measure of radioactivity)			
ppb	parts per billion, or micrograms per liter (µg/L)	PQL	Practical Quantitation Limit			
NA	Not applicable	ND	Not detected			
MNR	Monitored Not Regulated	Ng/L	Nanograms per Liter			
MPL	State Assigned Maximum Permissible Level	NR	Monitoring not required, but recommended.			
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG					
IVICEG	allow for a margin of safety.					
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as					
IVICL	feasible using the best available treatment technology.					
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.					
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.					
MRDLG	Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health.					
WINDLG	MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.					
MRDL	ximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a					
IVIINDL	disinfectant is necessary for control of microbial contaminants.					
Variances &	State or EPA permission not to meet an MCL or a treatment	echnique und	er certain conditions			
Exemptions	r					

PFAS - Per-and Polyfluoroalky Substances

The following table is **UnRegulated Contaminants** - The water system constantly monitors various contaminants in the water supply to meet all regulatory requirements. The tables list only those contaminants that has some level of detection. Many other contaminates have been analyzed but were not present or were below the detection limits of the lab requirement. This sampling was part of initial monitoring.

- PFAS are widely used, long lasting chemicals, components of which break down very slowly over time.
- Because of their widespread use and their persistence in the environment, many PFAS are found in the blood of people and animals all over the world and are present at low levels in a variety of food products and in the environment.
- PFAS are found in water, air, fish, and soil at locations across the nation and the globe.
- Scientific studies have shown that exposure to some PFAS in the environment may be linked to harmful health effects in humans and animals.
- There are thousands of PFAS chemicals, and they are found in many different consumer, commercial, and industrial products. This makes it challenging to study and assess the potential human health and environmental risks.

EPA's researchers and partners across the country are working hard to answer critical questions about PFAS:

- How to better and more efficiently detect and measure PFAS in our air, water, soil, and fish and wildlife
- How much people are exposed to PFAS
- How harmful PFAS are to people and the environment
- How to remove PFAS from drinking water
- How to manage and dispose of PFAS
- This information will help EPA and state, local, and tribal partners make more informed decisions on how best to protect human health and the environment.

Visit https://www.epa.gov/pfas/pfas-explained for more information.

Unregulated Contaminant Rule – PFAS (Per-and Polyfluoroalky Substances)							
Front Well / EP001							
Contaminant	MCL	Your Water	Tigger Level	PQL	Sampling Year	Typical Source of Contamination	
PFOA (ng/L)	4.0	2.8	2.0	4.0	2024	Byproducts of common household and commercial products.	
PFOS (ng/L)	4.0	2.4	2.0	4.0	2024	Byproducts of common household and commercial products.	
HFPO-DA (ng/L)	10	<0.3	5	5.0	2024	Byproducts of common household and commercial products.	
PFHxS (ng/L)	10	0.6	5	3.0	2024	Byproducts of common household and commercial products.	
PFNA (ng/L)	10	<0.5	5	4.0	2024	Byproducts of common household and commercial products.	
PFBS (ng/L)	NA	<0.5	NA	3.0	2024	Byproducts of common household and commercial products.	
Back Well / EP002							
Contaminant	MCL	Your Water	Tigger Level	PQL	Sampling Year	Typical Source of Contamination	
PFOA (ng/L)	4.0	13	2.0	4.0	2024	Byproducts of common household and commercial products.	
PFOS (ng/L)	4.0	0.9	2.0	4.0	2024	Byproducts of common household and commercial products.	
HFPO-DA (ng/L)	10	<0.4	5	5.0	2024	Byproducts of common household and commercial products.	
PFHxS (ng/L)	10	2.5	5	3.0	2024	Byproducts of common household and commercial products.	
PFNA (ng/L)	10	0.8	5	4.0	2024	Byproducts of common household and commercial products.	
PFBS (ng/L)	NA	3.9	NA	3.0	2024	Byproducts of common household and commercial products.	





